



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Tel/Fax: (800) 220-3675 / (856) 786-0262
<http://www.EMSL.com> / cinnmicrolab@emsl.com

Order ID: 371619508
Customer ID: MONE25
Customer PO: MCN0816.03
Project ID:

Attn: Charles Wirth (Ted)
Monarch Environmental, Inc.
PO Box 1986
Brighton, MI 48116

Telephone: (810) 220-2288
Fax: (810) 220-2313
Received Date: 10/11/2016
Processed Date: 10/11/2016
Analyzed Date: 10/21/2016

Project: MCN0816.03

Level 2 Legionella Detection - ID, Enumeration & Serotyping (1-14) of *L. pneumophila* by CDC Culture Method (EMSL Method M211)

Lab Sample ID	Client Sample ID / Sample Location	Volume Submitted (mL)	Volume Processed (mL)	Method Processed	Identification*	Final Result (CFU/mL)
371619508-0001	101016-1 Riverfront Building	1000	1000	Concentrated (acid treated)	<i>Legionella pneumophila</i> (sero 1)	2.5
371619508-0002	101016-2 Riverfront Building	1000	1000	Concentrated (acid treated)	<i>Legionella pneumophila</i> (sero 1)	0.9
371619508-0003	101016-3 Riverfront Building	1000	1000	Concentrated (acid treated)	<i>Legionella pneumophila</i> (sero 1)	2.1
371619508-0004	101016-4 Riverfront Building	1000	1000	Concentrated (acid treated)	<i>Legionella pneumophila</i> (sero 1)	0.9
371619508-0005	101016-5 Riverfront Building	1000	1000	Concentrated	None Detected	ND
371619508-0006	101016-6 Riverfront Building	1000	1000	Concentrated (acid treated)	<i>Legionella pneumophila</i> (sero 1)	0.9
371619508-0007	101016-7 Riverfront Building	1000	1000	Concentrated	None Detected	ND

Farbod Nekouei, M.S., Laboratory Director
or Other Approved Signatory

**Legionella* confirmations are carried out using a direct fluorescent antibody stain for *Legionella pneumophila* serogroup (1-14) and a stain for 20 other *Legionella* species and their respective serotypes.

ND = None Detected. Volumes processed may be lower than volumes submitted if sample is turbid, high non-*Legionella* bacterial counts are found during primary isolation, or suspected of containing high non-*Legionella* counts such as from a swab, bulk or non-potable water source. Samples high in non-*Legionella* bacteria may obscure the detection of *Legionella*.

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

The limit of detection (LOD) is the lowest reportable CFU count and is dependent on the sample volume submitted, prep volumes, and dilutions used in the testing. For typical water volumes submitted the LOD is 0.05 CFU/mL (1000 mL, Concentrated), 20 CFU/mL (1 mL, Acid Treated), and 10 CFU/mL (1 mL, Direct Plating). The LOD for swab samples is 100 CFU/swab (Acid Treated) or 50 CFU/swab (Direct Plating).

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC--EMLAP Accredited #100194, CDC ELITE certified

Initial Report From: 10/25/2016 14:21:49



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Tel/Fax: (800) 220-3675 / (856) 786-0262
<http://www.EMSL.com> / cinnmicrolab@emsl.com

Order ID: 371619508
Customer ID: MONE25
Customer PO: MCN0816.03
Project ID:

Attn: Charles Wirth (Ted)
Monarch Environmental, Inc.
PO Box 1986
Brighton, MI 48116

Telephone: (810) 220-2288
Fax: (810) 220-2313
Received Date: 10/11/2016
Processed Date: 10/11/2016
Analyzed Date: 10/21/2016

Project: MCN0816.03

Level 2 Legionella Detection - ID, Enumeration & Serotyping (1-14) of *L. pneumophila* by CDC Culture Method (EMSL Method M211)

Lab Sample ID	Client Sample ID / Sample Location	Volume Submitted (mL)	Volume Processed (mL)	Method Processed	Identification*	Final Result (CFU/mL)
371619508-0008	101016-8 Riverfront Building	1000	1000	Concentrated	None Detected	ND
371619508-0009	101016-9 Riverfront Building	1000	1000	Concentrated	<i>Legionella pneumophila</i> (sero 1)	0.4
371619508-0010	101016-10 Riverfront Building	1000	1000	Concentrated	None Detected	ND
371619508-0011	101016-11 Riverfront Building	1000	1000	Concentrated	None Detected	ND
371619508-0012	101016-12 Riverfront Building	1000	1000	Concentrated	None Detected	ND
371619508-0013	101016-13 Riverfront Building	1000	1000	Concentrated	None Detected	ND
371619508-0014	101016-14 Riverfront Building	1000	1000	Concentrated	None Detected	ND

Farbod Nekouei, M.S., Laboratory Director
or Other Approved Signatory

**Legionella* confirmations are carried out using a direct fluorescent antibody stain for *Legionella pneumophila* serogroup (1-14) and a stain for 20 other *Legionella* species and their respective serotypes.

ND = None Detected. Volumes processed may be lower than volumes submitted if sample is turbid, high non-*Legionella* bacterial counts are found during primary isolation, or suspected of containing high non-*Legionella* counts such as from a swab, bulk or non-potable water source. Samples high in non-*Legionella* bacteria may obscure the detection of *Legionella*.

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

The limit of detection (LOD) is the lowest reportable CFU count and is dependent on the sample volume submitted, prep volumes, and dilutions used in the testing. For typical water volumes submitted the LOD is 0.05 CFU/mL (1000 mL, Concentrated), 20 CFU/mL (1 mL, Acid Treated), and 10 CFU/mL (1 mL, Direct Plating). The LOD for swab samples is 100 CFU/swab (Acid Treated) or 50 CFU/swab (Direct Plating).

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC--EMLAP Accredited #100194, CDC ELITE certified

Initial Report From: 10/25/2016 14:21:49



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Tel/Fax: (800) 220-3675 / (856) 786-0262
<http://www.EMSL.com> / cinnmicrolab@emsl.com

Order ID: 371619508
Customer ID: MONE25
Customer PO: MCN0816.03
Project ID:

Attn: Charles Wirth (Ted)
Monarch Environmental, Inc.
PO Box 1986
Brighton, MI 48116

Telephone: (810) 220-2288
Fax: (810) 220-2313
Received Date: 10/11/2016
Processed Date: 10/11/2016
Analyzed Date: 10/21/2016

Project: MCN0816.03

Level 2 Legionella Detection - ID, Enumeration & Serotyping (1-14) of *L. pneumophila* by CDC Culture Method (EMSL Method M211)

Lab Sample ID	Client Sample ID / Sample Location	Volume Submitted (mL)	Volume Processed (mL)	Method Processed	Identification*	Final Result (CFU/mL)
371619508-0015	101016-15 Riverfront Building	1000	1000	Concentrated	None Detected	ND
371619508-0016	101016-16 Riverfront Building	1000	1000	Concentrated	None Detected	ND
371619508-0017	101016-17 Riverfront Building	1000	1000	Concentrated	None Detected	ND
371619508-0018	101016-18 Riverfront Building	1000	1000	Concentrated	<i>Legionella pneumophila</i> (sero 1)	0.55
371619508-0019	101016-19 Riverfront Building	1000	1000	Concentrated	<i>Legionella pneumophila</i> (sero 1)	0.15
371619508-0020	101016-20 Riverfront Building	1000	1000	Concentrated	<i>Legionella pneumophila</i> (sero 1)	3.7
371619508-0021	101016-21 Riverfront Building	1000	1000	Concentrated	<i>Legionella pneumophila</i> (sero 1)	2.75

Farbod Nekouei, M.S., Laboratory Director
or Other Approved Signatory

**Legionella* confirmations are carried out using a direct fluorescent antibody stain for *Legionella pneumophila* serogroup (1-14) and a stain for 20 other *Legionella* species and their respective serotypes.

ND = None Detected. Volumes processed may be lower than volumes submitted if sample is turbid, high non-*Legionella* bacterial counts are found during primary isolation, or suspected of containing high non-*Legionella* counts such as from a swab, bulk or non-potable water source. Samples high in non-*Legionella* bacteria may obscure the detection of *Legionella*.

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

The limit of detection (LOD) is the lowest reportable CFU count and is dependent on the sample volume submitted, prep volumes, and dilutions used in the testing. For typical water volumes submitted the LOD is 0.05 CFU/mL (1000 mL, Concentrated), 20 CFU/mL (1 mL, Acid Treated), and 10 CFU/mL (1 mL, Direct Plating). The LOD for swab samples is 100 CFU/swab (Acid Treated) or 50 CFU/swab (Direct Plating).

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC--EMLAP Accredited #100194, CDC ELITE certified

Initial Report From: 10/25/2016 14:21:49



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Tel/Fax: (800) 220-3675 / (856) 786-0262
<http://www.EMSL.com> / cinnmicrolab@emsl.com

Order ID: 371619508
Customer ID: MONE25
Customer PO: MCN0816.03
Project ID:

Attn: Charles Wirth (Ted)
Monarch Environmental, Inc.
PO Box 1986
Brighton, MI 48116

Telephone: (810) 220-2288
Fax: (810) 220-2313
Received Date: 10/11/2016
Processed Date: 10/11/2016
Analyzed Date: 10/21/2016

Project: MCN0816.03

Level 2 *Legionella* Detection - ID, Enumeration & Serotyping (1-14) of *L. pneumophila* by CDC Culture Method (EMSL Method M211)

Lab Sample ID	Client Sample ID / Sample Location	Volume Submitted (mL)	Volume Processed (mL)	Method Processed	Identification*	Final Result (CFU/mL)
371619508-0022	101016-22 Riverfront Building	1000	1000	Concentrated	<i>Legionella pneumophila</i> (sero 1)	2.35
371619508-0023	101016-23 Riverfront Building	1000	1000	Concentrated	<i>Legionella pneumophila</i> (sero 1)	10.05
371619508-0024	101016-24 Riverfront Building	1000	1000	Concentrated	<i>Legionella pneumophila</i> (sero 1)	8
371619508-0025	101016-25 Riverfront Building	1000	1000	Concentrated	<i>Legionella pneumophila</i> (sero 1)	7.15
371619508-0026	101016-26 Riverfront Building	1000	1000	Concentrated	<i>Legionella pneumophila</i> (sero 1)	2.15
371619508-0027	101016-27 Riverfront Building	1000	1000	Concentrated	<i>Legionella pneumophila</i> (sero 1)	0.75
371619508-0028	101016-28 Riverfront Building	1000	1000	Concentrated	<i>Legionella pneumophila</i> (sero 1)	0.65

Farbod Nekouei, M.S., Laboratory Director
or Other Approved Signatory

**Legionella* confirmations are carried out using a direct fluorescent antibody stain for *Legionella pneumophila* serogroup (1-14) and a stain for 20 other *Legionella* species and their respective serotypes.

ND = None Detected. Volumes processed may be lower than volumes submitted if sample is turbid, high non-*Legionella* bacterial counts are found during primary isolation, or suspected of containing high non-*Legionella* counts such as from a swab, bulk or non-potable water source. Samples high in non-*Legionella* bacteria may obscure the detection of *Legionella*.

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

The limit of detection (LOD) is the lowest reportable CFU count and is dependent on the sample volume submitted, prep volumes, and dilutions used in the testing. For typical water volumes submitted the LOD is 0.05 CFU/mL (1000 mL, Concentrated), 20 CFU/mL (1 mL, Acid Treated), and 10 CFU/mL (1 mL, Direct Plating). The LOD for swab samples is 100 CFU/swab (Acid Treated) or 50 CFU/swab (Direct Plating).

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC--EMLAP Accredited #100194, CDC ELITE certified

Initial Report From: 10/25/2016 14:21:49



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Tel/Fax: (800) 220-3675 / (856) 786-0262
<http://www.EMSL.com> / cinnmicrolab@emsl.com

Order ID: 371619508
Customer ID: MONE25
Customer PO: MCN0816.03
Project ID:

Attn: Charles Wirth (Ted)
Monarch Environmental, Inc.
PO Box 1986
Brighton, MI 48116

Telephone: (810) 220-2288
Fax: (810) 220-2313
Received Date: 10/11/2016
Processed Date: 10/11/2016
Analyzed Date: 10/21/2016

Project: MCN0816.03

Level 2 *Legionella* Detection - ID, Enumeration & Serotyping (1-14) of *L. pneumophila* by CDC Culture Method (EMSL Method M211)

Lab Sample ID	Client Sample ID / Sample Location	Volume Submitted (mL)	Volume Processed (mL)	Method Processed	Identification*	Final Result (CFU/mL)
371619508-0029	101016-29 Riverfront Building	1000	1000	Concentrated	<i>Legionella pneumophila</i> (sero 1)	0.5
371619508-0030	101016-30 Riverfront Building	1000	1000	Concentrated	<i>Legionella pneumophila</i> (sero 1)	0.35
371619508-0031	101016-31 Riverfront Building	1000	1000	Concentrated	<i>Legionella pneumophila</i> (sero 1)	4.35
371619508-0032	101016-32 Riverfront Building	1000	1000	Concentrated	<i>Legionella pneumophila</i> (sero 1)	0.15
371619508-0033	101016-33 Riverfront Building	1000	1000	Concentrated	<i>Legionella pneumophila</i> (sero 1)	0.4
371619508-0034	101016-34 Riverfront Building	1000	1000	Concentrated	<i>Legionella pneumophila</i> (sero 1)	0.65
371619508-0035	101016-35 Riverfront Building	1000	1000	Concentrated	<i>Legionella pneumophila</i> (sero 1)	1.5

Farbod Nekouei, M.S., Laboratory Director
or Other Approved Signatory

**Legionella* confirmations are carried out using a direct fluorescent antibody stain for *Legionella pneumophila* serogroup (1-14) and a stain for 20 other *Legionella* species and their respective serotypes.

ND = None Detected. Volumes processed may be lower than volumes submitted if sample is turbid, high non-*Legionella* bacterial counts are found during primary isolation, or suspected of containing high non-*Legionella* counts such as from a swab, bulk or non-potable water source. Samples high in non-*Legionella* bacteria may obscure the detection of *Legionella*.

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

The limit of detection (LOD) is the lowest reportable CFU count and is dependent on the sample volume submitted, prep volumes, and dilutions used in the testing. For typical water volumes submitted the LOD is 0.05 CFU/mL (1000 mL, Concentrated), 20 CFU/mL (1 mL, Acid Treated), and 10 CFU/mL (1 mL, Direct Plating). The LOD for swab samples is 100 CFU/swab (Acid Treated) or 50 CFU/swab (Direct Plating).

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC--EMLAP Accredited #100194, CDC ELITE certified

Initial Report From: 10/25/2016 14:21:49



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Tel/Fax: (800) 220-3675 / (856) 786-0262
<http://www.EMSL.com> / cinnmicrolab@emsl.com

Order ID: 371619508
Customer ID: MONE25
Customer PO: MCN0816.03
Project ID:

Attn: Charles Wirth (Ted)
Monarch Environmental, Inc.
PO Box 1986
Brighton, MI 48116
Project: MCN0816.03

Telephone: (810) 220-2288
Fax: (810) 220-2313
Received Date: 10/11/2016
Processed Date: 10/11/2016
Analyzed Date: 10/21/2016

Level 2 *Legionella* Detection - ID, Enumeration & Serotyping (1-14) of *L. pneumophila* by CDC Culture Method (EMSL Method M211)

Lab Sample ID	Client Sample ID / Sample Location	Volume Submitted (mL)	Volume Processed (mL)	Method Processed	Identification*	Final Result (CFU/mL)
371619508-0036	101016-36 Riverfront Building	1000	1000	Concentrated	<i>Legionella pneumophila</i> (sero 1)	0.1
371619508-0037	101016-37 Riverfront Building	1000	1000	Concentrated	<i>Legionella pneumophila</i> (sero 1)	0.3
371619508-0038	101016-38 Riverfront Building	1000	1000	Concentrated	<i>Legionella pneumophila</i> (sero 1)	0.45

Farbod Nekouei, M.S., Laboratory Director
or Other Approved Signatory

**Legionella* confirmations are carried out using a direct fluorescent antibody stain for *Legionella pneumophila* serogroup (1-14) and a stain for 20 other *Legionella* species and their respective serotypes.

ND = None Detected. Volumes processed may be lower than volumes submitted if sample is turbid, high non-*Legionella* bacterial counts are found during primary isolation, or suspected of containing high non-*Legionella* counts such as from a swab, bulk or non-potable water source. Samples high in non-*Legionella* bacteria may obscure the detection of *Legionella*.

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

The limit of detection (LOD) is the lowest reportable CFU count and is dependent on the sample volume submitted, prep volumes, and dilutions used in the testing. For typical water volumes submitted the LOD is 0.05 CFU/mL (1000 mL, Concentrated), 20 CFU/mL (1 mL, Acid Treated), and 10 CFU/mL (1 mL, Direct Plating). The LOD for swab samples is 100 CFU/swab (Acid Treated) or 50 CFU/swab (Direct Plating).

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC--EMLAP Accredited #100194, CDC ELITE certified

Initial Report From: 10/25/2016 14:21:49